



American Testing Materials Engineering, LLC.

Testing laboratories – Engineering Inspection Services – Chemist – Drilling – Environmental Services
 3876 SW. 30th Avenue, Hollywood, Florida 33312 – Phone: 954-587-2479 Fax: 954-791-6998

TEST BORING REPORT

CLIENT	RS Construction & Management LLC.		Order No.	14-0259	
ADDRESS	10031 Pines Blvd., Suite 239, Pembroke Pines, Florida 33024		Report No.	1	
PROJECT			Hole No.	B-1	
ADDRESS	3745 Frow Ave, Coral Gables, Florida		Date	04/10/14	
LOCATION	As marked on sketch		Driller	AL/JA	
DEPTH (FEET)	DESCRIPTION OF MATERIALS	Sample No.	Hammer blow on sampler	"N"	Hammer blows on casing
1	0'-0" to 2'-0" dark brown fine medium sand with lime rock		28	20	
2		0'-2'	20	16	40
3	2'-0" to 4'-0" lime rock with orange brown fine medium sand		16	18	
4		2'-4'	26	16	44
5	4'-0" to 6'-0" lime rock with orange brown fine medium sand		30	38	
6		4'-6'	48	40	86
7	6'-0" to 8'-0" lime rock with orange brown fine medium sand		50	For 1"	Refusal
8		6'-8'			
9	8'-0" to 10'-0" lime rock with light brown fine sand		25	22	
10		8'-10'	23	26	45
11	10'-0" to 14'-0" lime rock with light gray fine sand		33	38	
12		10'-12'	39	40	77
13			41	40	
14		12'-14'	33	33	73
15	14'-0" to 16'-0" lime rock with light gray fine sand		50	For 1"	Refusal
16		14'-16'			
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

WATER LEVEL: 8'-3" below surface
 At Date: 04-10-14

Respectfully Submitted,

Waseem Quadri
 Waseem Quadri, P.E. M. ASCE #51481
 Special Inspector - Threshold Buildings

As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



American Testing Materials Engineering, LLC.

Testing laboratories – Engineering Inspection Services – Chemist – Drilling – Environmental Services
 3876 SW. 30th Avenue, Hollywood, Florida 33312 – Phone: 954-587-2479 Fax: 954-791-6998

TEST BORING REPORT

CLIENT		RS Construction & Management LLC.		Order No.		14-0259	
ADDRESS		10031 Pines Blvd., Suite 239, Pembroke Pines, Florida 33024		Report No.		1	
PROJECT				Hole No.		B-2	
ADDRESS		3745 Frow Ave, Coral Gables, Florida		Date		04/10/14	
LOCATION		As marked on sketch		Driller		AL/JA	
DEPTH (FEET)	DESCRIPTION OF MATERIALS			Sample No.	Hammer blow on sampler		Hammer blows on casing
1	0'-0" to 2'-0" dark brown fine medium sand with lime rock				8	16	
2				0'-2'	22	31	38
3	2'-0" to 4'-0" lime rock with tan brown fine medium sand				38	42	
4				2'-4'	32	31	74
5	4'-0" to 6'-0" lime rock with tan brown fine medium sand				39	41	
6				4'-6'	44	49	85
7	6'-0" to 8'-0" lime rock with tan brown fine medium sand				48	49	
8				6'-8'	50	For 1"	refusal
9	8'-0" to 10'-0" lime rock with brown fine sand				47	40	
10				8'-10'	39	39	79
11	10'-0" to 12'-0" lime rock with light gray fine sand				47	48	
12				10'-12'	39	37	87
13	12'-0" to 14'-0" lime rock with light gray fine sand				50	For 1"	refusal
14				12'-14'			
15	14'-0" to 16'-0" lime rock with light gray fine sand				11	44	
16				14'-16'	36	39	80
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							

WATER LEVEL: 8'-3" below surface
 At Date: 04-10-14

Respectfully Submitted,

Waseem Quadri, P.E., M. ASCE #51481
 Special Inspector - Threshold Buildings

As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.