



American Testing Materials Engineering, LLC.


Testing laboratories – Engineering Inspection Services – Chemist – Drilling – Environmental Services
 3876 SW. 30th Avenue, Hollywood, Florida 33312 – Phone: 954-587-2479 Fax: 954-791-6998

TEST BORING REPORT

CLIENT		RS Construction & Management LLC.		Order No.		14-0259	
ADDRESS		10031 Pines Blvd., Suite 239, Pembroke Pines, Florida 33024		Report No.		1	
PROJECT				Hole No.		B-1	
ADDRESS		3797 Frow Ave, Coral Gables, Florida		Date		04/10/14	
LOCATION		As marked on sketch		Driller		AL/JA	
DEPTH (FEET)	DESCRIPTION OF MATERIALS	Sample No.	Hammer blow on sampler	"N"	Hammer blows on casing		
1	0'-0" to 2'-0" dark brown fine medium sand with lime rock		11	18			
2		0'-2'	19	19	27		
3	2'-0" to 4'-0" lime rock with orange brown fine medium sand		29	38			
4		2'-4'	39	42	77		
5	4'-0" to 6'-0" lime rock with orange brown fine medium sand		42	38			
6		4'-6'	44	40	82		
7	6'-0" to 8'-0" lime rock with orange brown fine medium sand		48	48			
8		6'-8'	40	37	88		
9	8'-0" to 10'-0" lime rock with light brown fine sand		32	28			
10		8'-10'	41	30	69		
11	10'-0" to 14'-0" lime rock with light gray fine sand		50	=for 1"	refusal		
12		10'-12'					
13			33	32			
14		12'-14'	34	38	66		
15	14'-0" to 16'-0" lime rock with light gray fine sand		38	39			
16		14'-16'	40	40	79		
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							

WATER LEVEL: 7'-4" below surface
 At Date: 04-10-14

Respectfully Submitted,



As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



American Testing Materials Engineering, LLC.

Testing laboratories – Engineering Inspection Services – Chemist – Drilling – Environmental Services
 3876 SW. 30th Avenue, Hollywood, Florida 33312 – Phone: 954-587-2479 Fax: 954-791-6998

TEST BORING REPORT

CLIENT		RS Construction & Management LLC.		Order No.		14-0259	
ADDRESS		10031 Pines Blvd., Suite 239, Pembroke Pines, Florida 33024		Report No.		1	
PROJECT				Hole No.		B-2	
ADDRESS		3797 Frow Ave, Coral Gables, Florida		Date		04/10/14	
LOCATION		As marked on sketch		Driller		AL/JA	
DEPTH (FEET)	DESCRIPTION OF MATERIALS	Sample No.	Hammer blow on sampler		Hammer blows on casing		
1	0'-0" to 2'-0" brown fine medium sand with traces of lime rock	0'-2'	7	17	44		
2			27	37			
3	2'-0" to 4'-0" lime rock with tan fine sand	2'-4'	33	32	72		
4			38	34			
5	4'-0" to 6'-0" lime rock with tan fine sand	4'-6'	40	41	83		
6			42	48			
7	6'-0" to 8'-0" lime rock with tan fine sand	6'-8'	33	38	77		
8			39	34			
9	8'-0" to 10'-0" lime rock with tan fine sand	8'-10'	50	+50			
10			For 1"	refusal			
11	10'-0" to 12'-0" lime rock with light gray fine sand	10'-12'	+50	For 1"			
12			Refusal				
13	12'-0" to 14'-0" lime rock with light gray fine sand	12'-14'	50	For 1"			
14			Refusal				
15	14'-0" to 16'-0" lime rock with light gray fine sand	14'-16'	+50	1"			
16			refusal				
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							

WATER LEVEL: 7'-4" below surface
 At Date: 04-10-14

Respectfully Submitted:

Waseem Quadri
 Waseem Quadri, P.E. M. ASCE #51481
 Special Inspector - Threshold Buildings
 No. 51481
 LICENSE
 PROFESSIONAL ENGINEER
 STATE OF FLORIDA

As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.